

List For Test Interval Standards and Requirements

PRODUCT	RECOMMENDED INTERVAL	REQUIRED INTERVAL	STANDARD REFERENCE
Gloves	Every 3 months	Before first issue; every 6 months thereafter	ASTM F496
Sleeves	Every 6 months	Before first issue; every 12 months thereafter	ASTM F496
Blankets	Every 6 months	Before first issue; every 12 months thereafter	ASTM F479
Line Hoses	Every 12 months	If damage suspected	ASTM F478
Cover Up Hoods	Every 12 months	If damage suspected	ASTM F478
Protective Grounds	Every 12 months	If damage suspected; after repair or modification	ASTM F2249
Hot Sticks Live Line Tools	Every 12 months	Every 2 years	ASTM F3121
Insulated Bucket Trucks	Every 6 months	Every 12 months	ANSI A92.2
Insulated Digger Derricks	Every 6 months	Every 12 months	ANSI A10.31
Bucket Liners	Every 6 months	Every 12 months	ANSI A92.2
Dielectric Footwear	Every 12 months	If damage suspected	ASTM F1116
Insulated Hand Tools	Every 12 months	If damage suspected	ASTM F1505

*** RE-TEST PPE AFTER PERFORMING ANY REPAIRS, MODIFICATIONS OR IF DAMAGE IS SUSPECTED TO ENSURE INTEGRITY ***

All services performed by Live Line Electrical Safety Services, LLC meet or exceed OSHA Code of Federal Regulations, OSHA 29 CFR §1910.335(a)(1)(ii) Protective equipment shall be maintained in a safe, reliable condition and shall be periodically inspected or tested, OSHA 29 CFR §1910.137.